

450 FG

SPECIFICATIONS

I. GENERAL

DESCRIPTION

Work included: Furnish all necessary material, labor and equipment for the complete installation of aluminum framing as shown on the drawings and specified herein. (Specifier Note: It is suggested that related items such as glass, sealants and entrances be included for single source responsibility.)

Work Not Included: Structural support of the framing system, interior closures, trim, metal sub-sills. (Specifier list other exclusions.)

Related Work Specified Elsewhere: (Specifier List).

QUALITY ASSURANCE

Drawings and specifications are based upon the 450 FG framing system as manufactured by CMI Architectural Products, Inc., De Smet, SD. Whenever substitute products are to be considered, supporting technical literature, samples, drawings and performance test data must be submitted ten (10) days prior to bid in order to make a valid comparison of the products involved. Test reports certified by an independent test laboratory must be made available upon request.

PERFORMANCE REQUIREMENTS

AIR INFILTRATION: Shall be tested in accordance with ASTM E 283. Air infiltration shall not exceed .06 CFM per square foot of fixed area.

STRUCTURAL PERFORMANCE: Shall be based on maximum deflection of L/175 of the mullion span and allowable stress with a safety factor of 1.5.

II. PRODUCTS

MATERIALS

Extrusions shall be 6063-T5 alloy and temper (ASTM B221 alloy G.S. 10A-T5). Fasteners used for assembly, shall be aluminum, stainless, or zinc plated steel in accordance with ASTM A 164-71. Perimeter anchors shall be stainless steel, or zinc plated steel. (Anchors are provided by the glazing contractors). Glazing gaskets shall be E.P.D.M., Elastomeric or Neoprene.

FINISH

All exposed aluminum surfaces shall be free of scratches and other serious blemishes. All exposed surfaces shall be given a caustic etch followed by an anodic oxide treatment to obtain the following finish: (Specifier select).

An Architectural Class II clear anodic coating in accordance with the Aluminum Association Standard AA-M12 C22 A31 designated as #20 Clear.

An Architectural Class I anodic coating with integral color in accordance with the Aluminum Association Standard AA-M12 C22 A44 designated as #33 Dark Bronze.

(Specifier note: Champagne, Lt. Bronze, Medium Bronze, Black, are available colors offered at a premium price.)

ORGANIC COATING: High performance fluorocarbon coatings in accordance with AAMA 2605. Color as selected by Architect and offered at a premium price.

FABRICATION

The framing members shall provide for flush glazing on all sides with no projecting stops. Vertical and horizontal framing members shall have a nominal face dimension of 1-3/4". Overall depth shall be 4-1/2". Door framing members shall be compatible with glass framing members in appearance.

III. EXECUTION

INSTALLATION

All aluminum frames shall be installed in their prepared openings as detailed and shall be level, square, plumb, and according to manufacturer's instructions and approved shop drawings. Perimeter shims shall be located under glass setting blocks, vertical mullions, and as additionally necessary. All joints between framing and the building structure shall be sealed at both interior and exterior in order to secure a weather tight installation. Weep holes shall be installed per manufacturers shop drawings.

PROTECTION AND CLEANING

After installation, the General Contractor shall protect exposed aluminum surfaces from damage by other trades. The General Contractor shall be responsible for the final cleaning.

(NOTE: Product improvements may require specification changes without notice.)